WELL ABANDONMENT RECORD

North Carolina Department of Environment and Natural Resources- Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2609

1. WELL CONTRACTOR:

NEILL PARDUE
Well Contractor (Individual) Name

AIR DRILLING, INC.
Well Contractor Company Name

STREET ADDRESS 176 COMMERCE BLVD

STATESVILLE NC 28625
City or Town State Zip Code

(704) - 872-7614
Area code - Phone number

2. WELL INFORMATION:

SITE WELL ID # (if applicable)

STATE WELL PERMIT # (if applicable)

COUNTY WELL PERMIT # (if applicable) 206897

DWQ or OTHER PERMIT # (if applicable)

WELL USE (Check applicable use): ☐ Monitoring ☑ Residential

☐ Municipal/Public ☐ Industrial/Commercial ☐ Agricultural

☐ Recovery ☐ Injection ☐ Irrigation

☐ Other (list use)

3. WELL LOCATION:

COUNTY IREDELL QUADRANGLE NAME

NEAREST TOWN: UNION GROVE

1168 MYER'S MILL RD.
(Street/Road Name, Number, Community, Subdivision, Lot No., Parcel, Zip Code)

TOPOGRAPHIC / LAND SETTING:

☐ Slope ☐ Valley ☐ Flat ☐ Ridge ☐ Other
(Check appropriate setting)

LATITUDE 36° 01. 178

LONGITUDE 80° 54. 280

May be in degrees, minutes, seconds, or in a decimal format

Latitude/longitude source: ☐ GPS ☐ **Topographic map**

(Location of well must be shown on a USGS topo map and attached to this form if not using GPS.)

4a. FACILITY- The name of the business where the well is located. Complete 4a and4b. (If a residential well, skip 4a; complete 4b, well owner information only.)

FACILITY ID #(if applicable)

NAME OF FACILITY

STREET ADDRESS

City or Town State Zip Code

4b. CONTACT PERSON/WELL OWNER:

NAME SCOTT COLEMAN

STREET ADDRESS 1168 MYER'S MILL RD.

Union Grove, NC 28689

5. WELL DETAILS:

a. Total Depth: 160 ft. Diameter: 6 in.

b. Water Level (Below Measuring Point): ft.

Measuring point is ft. above land surface.

6. CASING:

	Length	Diameter
a. Casing Depth (if known):	N/A ft.	in.
b. Casing Removed:	N/A ft.	in.

7. DISINFECTION: HTH

(Amount of 65%-75% calcium hypochlorite used)

8. SEALING MATERIAL:

Neat Cement

Cement — lb.
Water — gal.

Sand Cement

Cement — lb.
Water — gal.

Bentonite

Bentonite lb.

Type: ☐ Slurry ☐ Pellets

Water gal.

Other

Type material CONCRETE

Amount 1 1/4 YARDS

9. EXPLAIN METHOD OF EMPLACEMENT OF MATERIAL:

POURED

10. WELL DIAGRAM: Draw a detailed sketch of the well on the back of this form showing total depth, depth and diameter of screens (if any) remaining in the well, gravel interval, intervals of casing perforations, and depths and types of fill materials used.

11. DATE WELL ABANDONED 12/15/14

I DO HEREBY CERTIFY THAT THIS WELL WAS ABANDONED IN ACCORDANCE WITH 15A NCAC 2C WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Neill Pardue 12/15/14

SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

SIGNATURE OF PRIVATE WELL OWNER ABANDONING THE WELL DATE
(The private well owner must be an individual who personally abandons his/her residential well in accordance with 15A NCAC 2C .0113.)

NEILL PARDUE
PRINTED NAME OF PERSON ABANDONING THE WELL

Submit a copy to the owner and the original to the Division of Water Quality within 30 days.
Attn: Information Management, 1617 Mail Service Center – Raleigh, NC 27699-1617, Phone No. (919) 733-7015 ext 568.

Form GW-30
Rev. 5/06