IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James Jordan DATE Feb 3, 1978 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Jennings Rd. N. T.L. at Jennings Store onto S.R. 1857 Go ~ 1.3 mi on left. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 2 Ac.


Character & Porosity of Soil Cecil clay loam

Percolation Rate —

Topography Hilly

Depth to Water Table unk.

Rock or other impervious formations none obs.



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 600 Linear Ft. 200

Depth of Stone in Lines 16"

Water Supply: Individual (✓)

Public ( )

Installed by James Hartman

IMPROVEMENTS PERMIT BY H. R. Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Harold R. Hinson DATE Feb 3, 1978

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold