IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Grassy Knob Parsonage Dexter Henderson DATE 4-12-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115 N TR on 901 – TL on SR 1804 Grassy Knob Ch. Rd. ¾ mile down from Church S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay Loam
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	1
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	6-10% slopes
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	none
			Rock or other impervious formations	none

Lot Area ¾ acre



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 675 Linear Ft. 225

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public ( )

water from church

Installed by Charlie Moore

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Gobble DATE 4/12/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold