IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Rev Paul Carter DATE 6 Dec 74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Jennings Rd 901 T.L. to St Rd 1804 — Rgt to St 1805 on Rgt approx .8 mi 1st trailer house on Rgt Mobile Home trailer house S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1½

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Red Clay
Percolation Rate 10 min
Topography Slope to front of Lot
Depth to Water Table 4 ft
Rock or other impervious formations 6 ft

Lot Area acreage



Plot of System #1805

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 675 Linear Ft. 150
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Jesse Horton

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Wm Howard DATE 6 Dec 74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold