DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #:
COUNTY: Pasquotank
4840612918 (PAA)

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: R.C. GATTON APPLICANT: SAME
ADDRESS: 125 GETHSEMANE RD APPLICATION DATE: 6/12/97 DATE EVALUATED: 6/24/97
PROPOSED FACILITY: 2BR SIW MH PROPOSED DESIGN FLOW (.1949): 240 PROPERTY SIZE: 0.99 ACRE
LOCATION OF SITE: US 21 N, TL JENNINGS, TL GETHSEMANE, ON LEFT PROPERTY RECORDED:
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAF
1	N 4%	0-4	GR / SCL	VFR / NEXP	—	PS	PS	—	PS 0.33
		4-42	WF SBK / CL	FR / NEXP					
		42+	SCL SAPROLITE	VFR / NEXP					
2	N 6%	0-4	GR / SCL	VFR / NEXP	—	PS	PS	—	PS 0.33
		4-38	WF SBK / CL	FR / NEXP					
		38-48	WFSBK / CL/SAP.	VFR / NEXP					
3	L 4%	0-2	GR / SCL	VFR / NEXP	—	PS	PS	—	PS 0.33
		2-48	WFSBK / CL	FR / NEXP					
4	H 6%	0-6	GR / SCL	VFR / NEXP	—	PS	PS	—	PS 0.33
		6-48	WFSBK / CL	FR / NEXP					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	II	III
Site LTAR	0.33	0.33

OTHER FACTORS (.1946): NONE / EASEMENT
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S HEDRICK
OTHER(S) PRESENT: R.C. GATTON