IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Charles Taylor DATE 18 June 76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Jennings Rd N. paved Rd Russell School to Rd 1894 on left 1st house left S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 1

Garbage Disposal Unit	Yes	( )	No	(✓)	Character & Porosity of Soil: Sand Clay
Auto. Dishwasher	Yes	( )	No	(✓)	Percolation Rate: none
Auto. Wash. Machine	Yes	(✓)	No	( )	Topography: 2-6 % slope
Site Suitable	Yes	(✓)	No	( )	Depth to Water Table: 6'
					Rock or other impervious formations: 6'

Lot Area Average



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 5
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Ray Long

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 18 June 76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold