IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Donnie Frye DATE Sept. 14, 1977 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Jennings Rd. N. behind 1st house on left past Idyll Down Trailer Park

SUBDIVISION NAME _____ S. R. No. _____

LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 7 Ac.


Character & Porosity of Soil Cecil loam

Percolation Rate —

Topography 4% slope

Depth to Water Table unk

Rock or other impervious formations none obs.



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 18"

Water Supply: Individual (✓)

Public ( )

Installed by Hoke Bros.

IMPROVEMENTS PERMIT BY A. E. Causey

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Harold R. Hinson DATE Sept. 14, 1977

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold