DEPARTMENT OF ENVIRONMENT, HEALTH & [illegible]
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: [illegible]
COUNTY: IREDELL

4840 96 7469.

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: LUCIA SARCONA APPLICANT: JIM PEELER / INTEGRITY
ADDRESS: 400 DUTCHNECK, EASTWINDSON, NJ APPLICATION DATE: _____ DATE EVALUATED: 1-19-99
PROPOSED FACILITY: 3BR D/W MH PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 1.833 ACRES
LOCATION OF SITE: GLEN ACRES #2 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☑ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	SLIGHT N 4%	0 30	WMSBK / C	FI / NEXP	–	–	–	–	PS 0.3
		30 98	WMSBK / SCL	FR / NEXP					
2	SLIGHT N 4%	0 32	WMSBK / C	FI / NEXP	–	–	–	–	PS 0.3
		32 48	WMSBK / SCL	FR / NEXP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	II
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S HEDRICK
OTHER(S) PRESENT: _____