IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ralph Adams DATE 9-18-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21N Tr on Jennings Rd. Tr on Mt Vernon Ch. Rd #1880 Go approx 1 3/10 mile Mobile Home on left Door in field S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil Clay
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	Fast
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-6% slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	Unk
			Rock or other impervious formations	None

Lot Area 6 acres



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Henry Sizemore

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Foard DATE 9/18/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold