DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: IREDELL

4841 14 0886 (PT)

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: JASON WOOD APPLICANT: SAME
ADDRESS: 7746 SHERRILLS FORD, STATESVILLE, NC APPLICATION DATE: 9-17-99 DATE EVALUATED: 10-1-99
PROPOSED FACILITY: 3BR DW MH PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 1.002 ACRE
LOCATION OF SITE: LOT #4 NORTH POINT ESTATES PROPERTY RECORDED: ___
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	SLIGHT H 15%	0-24	SBK / C	FI / NEXP					PS 0.35
		24-48	SBK / CL	FR / NEXP					
2	L 15%	0-20	SBK / C	FI / NEXP					PS 0.35
		20-48	SBK / CL	FR / NEXP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	III	III
Site LTAR	0.35	0.35

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HENDRICK
OTHER(S) PRESENT: JASON WOOD