IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

11837

OWNER OR CONTRACTOR EDWARD G. SLOAN DATE 8/17/90 PERMIT NO 130-A-6

PHONE: Business _____ Home _____

LOCATION US 21 N. TL JENNINGS, TL MT. VERNON, 3RD DRIVE ON (R) (L) S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Character & Porosity of Soil PROV. SUITABLE
Percolation Rate 4
Topography 6-10%
Depth to Water Table 24"
Rock or other impervious formations SHALLOW ROCK / SAPROLITE

Lot Area AMPLE

(✓) Basement with Plumbing ( ) Basement without Plumbing ( ) No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by JOHN MENSCER

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY STEVE HENDRICK / GLENN FOX, JR

COMMENTS: _____

CERTIFICATE OF COMPLETION BY STEVE HENDRICK / STEVE BROWN DATE 8/17/90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

The location of the proposed 30' x 50' GARAGE addition does not appear to impact the existing septic system.
**NOTE: KEEP MINIMUM 5' FROM SYSTEM
R. STEVE HENDRICK REHS
Date: FEB 15, 2011
ICHD-Environmental Health Division