HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 16(5).A-25
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: ELIZABETH LARSON OWNER: AGENT: PHONE: 592-2125 / 876-0096
ADDRESS: P.O. BOX 56 APPLICATION DATE: 12/9/93 DATE EVALUATED: 12/9/93
OLIN, NC 28660 PROPOSED FACILITY: 3BR MH
PROPERTY SIZE: ~1 ACRE
LOCATION OF SITE: JENNINGS RD N, TL WEISNER, TL CURRENT, ON L ~ 0.3 MILE
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS / SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	H 4-6	0-30	C	ABK	1:1 / FI	.1942 WETNESS CONDITION S
		30-48	C	SBK	1:1 / FR	.1943/.1956 SAPROLITE S
						.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.30
2	H 4-6	0-28	C	ABK	1:1 / FI	.1942 WETNESS CONDITION S
		28-42	C	SBK	1:1 / FR	.1943/.1956 SAPROLITE S
						.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.30
3						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
4						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
5						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.30
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S HEDRICK OTHER(S) PRESENT: ELIZABETH LARSON & DAUGHTER
COMMENTS:

DRAFT

000069