IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Larry L. Austin DATE 31 Aug 76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Jennings Rd N to Hall on left just passed N. Vernon Ch. Rd

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area average


Character & Porosity of Soil Cecil Cly

Percolation Rate none

Topography 2-6% slope

Depth to Water Table nl

Rock or other impervious formations nl



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 564± Linear Ft. 225
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: New mobile home being moved in place of existing mobile home. Existing mobile home to be set up on back of property for storage - not to be used as residence until a separate septic tank system is installed.

CERTIFICATE OF COMPLETION BY Will Tolbert DATE 31 Aug 76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold