HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: T6D-A-38
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: CALVIN SELL OWNER: ✓ AGENT: PHONE: 876-1732
ADDRESS: Rt. 1, Box 275 APPLICATION DATE: 7/1/94 DATE EVALUATED: 7/7/94
OLIN, NC PROPOSED FACILITY: PICNIC SHELTER @ 150 GAD
28660 PROPERTY SIZE: 65.84 AC
LOCATION OF SITE: INTERSECTION OF JENNINGS & WEISNER RD
WATER SUPPLY: On-Site Well 1 Comm. Well Public ✓ Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINERALOGY	
1	L 6%	0-30	C	SBK	1:1 / FI	.1942 WETNES CONDITION S
		30-48	SC	SBK	1:1 / FR	.1943/.1956 SAPROLITE S
						.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.35
2	L 6%	0-40	C	SBK	1:1 / FI	.1942 WETNES CONDITION S
		40-48	SC	SBK	1:1 / FR	.1943/.1956 SAPROLITE S
						.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.35
3						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
4						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
5						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: CALVIN SELL
COMMENTS:

DRAFT

0021 62