IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281 (C1)

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 148645 PIN# 4842-12-0583 DATE 4-9-08

OWNER OR APPLICANT JONATHAN B. WHITE PHONE: Business 704-746-7094 Home 704-876-4191

ADDRESS 238 TRUMPET BRANCH ROAD, OLIN NC 28660

LOCATION JENNINGS ROAD TO TRUMPET BRANCH ROAD, ~ 0.7 MILE ON RIGHT

SUBDIVISION _____ BLOCK / SECTION _____ LOT _____ LOT AREA 7.0 ACRES SITE CLASS. PS DESIGN FLOW 480 L.T.A.R EXISNR

Septic Tank: 1000 Gallons; STB _____ Date _____

Pump Tank: _____ Gallons; PT _____ Date _____

Pump Make: _____ Model _____ Serial No. _____

Nitrification Field: No Fields 1 Square Feet 1600 Linear Feet 533

No Lines FOUR Trench Width _____ Max Trench Bottom Depth _____ Gravel Depth 12" ☒ Gravity ☐ Pressure

☐ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: CONVENTIONAL, GRAVITY

Repair System Description: CONVENTIONAL, GRAVITY

Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Persons ____

☐ Business No. Employees ____

☐ Other _____

Water Supply: ☐ Individual ☒ Public ☐ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:

Comments:/Conditions: SEE ATTACHED EASEMENT FOR CROSSING PROPERTY LINE & EXISTING S/W MH TO BE REMOVED UPON OCCUPANCY OF HOUSE

INITIAL SITE SKETCH

AS BUILT SKETCH

~SCALE 1" = 100'

(THIS IS NOT A SURVEY)

now sewer line actually came out

TRUMPET BRANCH ROAD

DRIVEWAY

PROPERTY LINE 882'

POOL

HOUSE

DECK

SEPTIC TANK

67'

100'

EROSION SENCE

Location of the proposed swimming pool addition does not appear to impact the existing on-site septic system.NOTE:**

REHS

Date: 7-18-12

ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☐ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____ date _____ Installed by: _____

Improvement Permit by: _____ date _____ Operation Permit by: _____ date _____

Authorization to Construct by: _____ date _____ Existing System Inspection by: STEVE HENDRICK date 4-9-08

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK