DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of _
PROPERTY ID #: 4842-24-0962
COUNTY: IREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: RENEE V. OSBORNE APPLICANT: SAME
ADDRESS: 1381 JENNINGS RD, STATESVILLE, NC APPLICATION DATE: 9-27-01 DATE EVALUATED: 10-26-01
PROPOSED FACILITY: 3BR MOD. H PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 6 ACRES
LOCATION OF SITE: US 21 N, TL JENNINGS, TL EUPHONIC SPRINGS, 0.3mi on L PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAF
1	SLIGHT N 6%	0-8	SBK GRAVELLY C	FI SEXP					PS 0.3
		8-30	SBK C	FR SEXP					
		30-48	WSBK SiC	VFR SEXP					
2	SLIGHT N 8%	0-8	SBK GRAVELLY C	FI SEXP					PS 0.3
		8-34	SBK C	FR SEXP					
		34-48	WSBK SiC	VFR SEXP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	II
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HEDRICK
OTHER(S) PRESENT: RENEE V OSBORNE