DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ____ of ____
PROPERTY ID #:
COUNTY: Bladen

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

4842 26 6375
PAGE 1 OF 2

OWNER: FLEETWOOD HOMES OF SOUTHERN VIEW APPLICANT: SAME
ADDRESS: 1270 NORTHSIDE DR, ST JUL APPLICATION DATE: 8-2-02 DATE EVALUATED: 9-6-02
PROPOSED FACILITY: 4BR D/W PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: 1 ACRE
LOCATION OF SITE: JENNINGS RD TO EUPHONIC SPRINGS RD, PAST 9TH S/W ON R PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	L 8%	0-24	SBK CL MIX SAPROLITE	FR SS/SP SEP					4
		24"+	ROCK						
2	L 7%	0-40	SBK C	FR SS/SP SLVP					PS 0.3
		40+	SAPROLITE MIX W/ WEATHERED ROCK						
3	L 8%	0-40	SBK C	FR SS/SP SEP					PS 0.3
		40+	SAPROLITE MIX W/ WEATHERED ROCK						
4	L 2%	0-40	SBK CL	FR SS/SP SEP					PS 0.35
		40+	SAPROLITE						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: STEVE HEDRICK
OTHER(S) PRESENT: CHRIS GUNTER