DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID#:
COUNTY:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: MIKE Keller
ADDRESS: APPLICANT:
PROPOSED FACILITY: APPLICATION DATE: DATE EVALUATED:
LOCATION OF SITE: Eupptic Springs Lot 4 PROPERTY SIZE:
WATER SUPPLY: ☑ Private ☐ Public ☐ Well ☑ Spring ☐ Other PROPERTY RECORDED:
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LAND SCAPE POSITION SLOPE %	HORIZON DEPTH (IN)	SOIL MORPHOLOGY (1941) 1941 STRUCTURE/ TEXTURE	1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1950 SAPRO CLASS	1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	3-4%	0-8	SCL GR	FRI SSSP					3 PS
		8-34	LC SBK	FI SP					
		34+	Rock						
2		0-4	SCL GR	FRI SS SP					3 PS
		4-36	RC SBK	FI SP					
		36+	Saprolite/Rock						
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948):
EVALUATED BY:
OTHER(S) PRESENT: