HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 16G-A-118
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: JACK L. CREASY OWNER: ✓ AGENT: PHONE: 872-2411 539-5258
ADDRESS: 3261 JENNINGS RD APPLICATION DATE: 3/27/95 DATE EVALUATED: 4/4/95
OLIN, NC 28660 PROPOSED FACILITY: 3BL HOUSE
PROPERTY SIZE: ~5.0 ACRES
LOCATION OF SITE: JENNINGS POND RD (SR) NORTH OF ROCKY CREEK
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ✓ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY	
1	L 18%	0-32	C	ABK	1:1 / FI	.1942 WETNES CONDITION 5
		32-48	SC/SND	SBK	1:1 / FR	.1943/.1956 SAPROLITE 5
						.1944 RESTRICTIVE HORIZON 5
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.3
2	N 12%	0-28	C	ABK	1:1 / FI	.1942 WETNES CONDITION 5
		28-48	SC/SNP	SBK	1:1 / FR	.1943/.1956 SAPROLITE 5
						.1944 RESTRICTIVE HORIZON 5
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.3
3						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
4						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
5						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR

AVAILABLE SPACE (.1945) 5 SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.3 GPD/FT²
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: JACK L. CREASY
COMMENTS:

DRAFT