IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

10-29f

OWNER OR CONTRACTOR John Carter Jr DATE 8-9-89 PERMIT NO. 166-A-59

PHONE: Business _____ Home _____

LOCATION Jennings West Tamarpot Br 2nd dwelling on Right

SUBDIVISION NAME _____ S. R. No. _____

LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 6 AC

Character & Porosity of Soil Sandy Loam/Gravelly
Percolation Rate 41
Topography Slope
Depth to Water Table 10'+
Rock or other impervious formations Scattered Rock

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 300 Linear Ft. 300
Depth of Stone in Lines 24"
Water Supply: Individual (✓)
Public ( )

Installed by A/Backhoe

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY [signature]

COMMENTS: _____

CERTIFICATE OF COMPLETION BY [signature] DATE 8-9-89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold