06883

I

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR JODY E. HOOTS DATE 6-18-87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION I-77 N-T.L. on Hwy 90 T.L. on Sloans Mill Rd. at Union Grove School-T.R. on Bassett Rd. - ½ mi. on R. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 124 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other Mfg. built home (Septic system) to tie into this S.T. system if mobile home is removed.


No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Prev. suitable
Percolation Rate 5 gal/sq. ft.
Topography 2-6%
Depth to Water Table 6'+
Rock or other impervious formations none observed.

Lot Area 2.5 acres

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 24"

Water Supply: Individual ( )
Public (✓)

Installed by Darrin Hollibee

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 6-18-87

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold