IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Union Grove Swimming and Recreation Club. DATE 14 Apr 77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION I-77N to Hwy 901 T.L. to Union Grove approx 1 mile - Swimming on right - Lake Norman Rd S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other Recreation Club approx 100 members

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes	( )	No	( )
Auto. Dishwasher	Yes	( )	No	( )
Auto. Wash. Machine	Yes	( )	No	( )
Site Suitable	Yes	( )	No	( )

Lot Area _____


Character & Porosity of Soil Coral Clay

Percolation Rate none

Topography 2-6% slope

Depth to Water Table 2'

Rock or other impervious formations 2'



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 1000 Linear Ft. 400

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by James Hartness

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY W. M. Howard DATE 14 Apr 77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold