IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Clyde White DATE 28 Nov 75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION I-77 N to 901. T left. Go to paved stud just before elementary school. Trailer park on left of 901. 5th Track on right. S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay Loam
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	none
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-6% Slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	6'
			Rock or other impervious formations	No

Lot Area _____



Plot of System

Size of Tank Equity 1000 gals.

Nitrification Field:
No. of Lines _____
Sq. Ft. _____ Linear Ft. _____
Depth of Stone in Lines _____

Water Supply: Individual ( )
Public ( )

Installed by _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: Equity System - 2 trailers on system before - functioned properly - is presently functioning properly. If system gives trouble, it must be upgraded to specifications of Rules Governing Individual Sewage Disposal Systems.

CERTIFICATE OF COMPLETION BY [illegible] DATE 28 Nov 75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold