IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Lewis Myers DATE May 12, '78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION I-77N T.L. on 901 T.L. on SR 1946 ~.3mi. on Lft

S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (+) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit Yes ( ) No (+)
Auto. Dishwasher Yes (+) No ( )
Auto. Wash. Machine Yes (+) No ( )
Site Suitable Yes (+) No ( )
Lot Area 1½ ac.

Character & Porosity of Soil Cecil clay loam
Percolation Rate _____
Topography 2-4%
Depth to Water Table >4'
Rock or other impervious formations none obs.



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 16"+
Water Supply: Individual (+)
Public ( )

Installed by Donald Lackey

IMPROVEMENTS PERMIT BY H. R. Henson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Harold R. Henson DATE May 12, '78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold