IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR FARMERS CAFE DATE 5-28-82 PERMIT NO. _____

PHONE Business _____ Home _____

LOCATION Union Grove - across from Union Grove Vol. Fire Dept.

S R N _____


SUBDIVISION NAME _____ LOT NO _____ SECTION OR BLOCK NO _____

House ( ) Mobile Home ( ) Business (✓) Other Restaurant

No. Bedrooms ___	No. Bathrooms 2	Character & Porosity of Soil	CFC 2
Garbage Disposal Unit	Yes ( ) No ( )	Percolation Rate	1 gal/sq ft.
Auto. Dishwasher	Yes ( ) No ( )	Topography	2 6%
Auto. Wash Machine	Yes ( ) No ( )	Depth to Water Table	10+
Site Suitable	Yes ( ) No ( )	Rock or other impervious formations	none encountered

Lot Area Ample

(✓) Basement with Plumbing ( ) Basement without Plumbing ( ) No Basement



Plot of Section

Size of Tank 1500 Gals

Nitrification Field

No. of Lines 7

Sq. Ft. 350 Linear Ft. 750

Depth of Stone in Lines 10" ±

Water Supply Individual (✓)
Public ( )

1,000 gal. precast tank

Installed by Jones Heaters

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Glenn Hall Jr.

COMMENTS _____

CERTIFICATE OF COMPLETION BY Glenn Brown DATE 5-28-82

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit

Health Dept. Copy White Inspection Dept. Copy Yellow Sanitarian's Copy Pink Owner's Copy Gold