40224

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

12757 PT

OWNER OR CONTRACTOR DOUGLAS HOLLAND DATE 9/16/91 PERMIT NO. 132-A-91A

PHONE: Business _____ Home _____

LOCATION OLIN ROAD ACROSS FROM WILLIAMSBURG ROAD INTERSECTION. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2½


Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil PS
Percolation Rate .4 GPD / FT²
Topography 2 - 6%
Depth to Water Table >4'
Rock or other impervious formations NONE

Lot Area ~1 AC

_____ Basement with Plumbing ✓ Basement without Plumbing _____ No Basement

ACP 7/30/91



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (✓) WELL
Public ( )

Installed by DAVID YOUNTS

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY J. C. MOORE

COMMENTS: _____

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 9/10/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold