IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR J. L. Spence DATE 28 Mar 74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Jennings Rd N to #1891 - 4th house on Rt. yellow Lopsy corner. Across from Ollie Byrd's S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	~~Yes (✓)~~	No ( )

Lot Area 20,100 sq ft


Character & Porosity of Soil Red Clay loam

Percolation Rate one

Topography Slope to rear

Depth to Water Table ind

Rock or other impervious formations ind



Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines _____

Water Supply: Individual ( )
Public ( )

Installed by Owner Operated

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY William M Howard DATE 29 Mar 74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold