44396

IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

150006

OWNER OR CONTRACTOR BRIAN SAFRIT DATE 11/16/92 PERMIT NO. 16B-A-24

PHONE: Business _____ Home _____

LOCATION I-77 N, TL NC901W TL SLOAN MILL ROAD, ON (R) ACROSS FROM COWDEN FORD ROAD S.R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ☑ Mobile Home ☐ Business ☐ Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ☐ No ☑

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area AMPLE

Soil Characteristics PS

Application Rate 0.35 GPD/FT2

Topography 2-4% ~LINEAR

Depth to Water Table 54"

Rock or other impervious formations NONE

1 Basement with Plumbing _____ Basement without Plumbing _____ No Basement ✓ Crawl Space

ACP 7/8/92

Size of Tank 1000 Gals.


Nitrification Field:

No. of Lines 3

Sq. Ft. 1035 Linear Ft. 345

Depth of Stone in Lines 12"

Water Supply: Individual ☐ Public ☑



Plot of System (Not to Scale)

Installed by A-1 BACKHOE

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY STEVE HEDRICK

COMMENTS REPAIR AREA IS 100% CONVENTIONAL GRAVITY-FED

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 11/16/92

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

COWDEN FORD ROAD

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold