IREDELL COUNTY HEALTH DEPARTMENT

11938 (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR LISA LOWE DATE 9/21/90 PERMIT NO. IredB-A-17-91

PHONE: Business _____ Home _____

LOCATION I-77 N, TR ON NC 901 S, TR JERICHO RD, GO ~2 mi, MH on (R) IN WOODED AREA S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Character & Porosity of Soil .4 PS
Percolation Rate .4 2-6" in LS
Topography
Depth to Water Table 10'+
Rock or other impervious formations NONE

Lot Area 1 3/8 AC.


_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

TP 6/30/90

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )



Plot of System

Installed by KENNY PEARSON

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY GLENN FOX, JR

COMMENTS: KEEP WELL 50' MINIMUM FROM SYSTEM

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 9/21/90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold