DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: IREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: JAMES HADEN APPLICANT: SAME
ADDRESS: P.O. BOX 1651, STVL, 28687 APPLICATION DATE: 8-13-99 DATE EVALUATED: 8-25-99
PROPOSED FACILITY: 3BR D/W MH PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 1.15 ACRES
LOCATION OF SITE: JERICHO RIDGE #5 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	N 6%	0-48	SBK / CL	FR / NEXP					PS 0.33
2	L 8%	0-48	SBK / CL	FR / NEXP					PS 0.33
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	III
Site LTAR	0.33	0.33

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS

EVALUATED BY: S. HEDRICK
OTHER(S) PRESENT: JAMES HADEN