IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Albert Chumley DATE 15 Apr 76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION I 77 N to 901 T.L. to R Ist road then left. to R end of road. T.L. in 1852 2nd house on left S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 1 acre

Character & Porosity of Soil Red Clay
Percolation Rate none
Topography 2-6% Slope
Depth to Water Table ok
Rock or other impervious formations ok



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 635 Linear Ft. 289'
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Jesse Hartness

IMPROVEMENTS PERMIT BY _____

COMMENTS: Line Inst. ditch rock and pipe and have ent. of site

CERTIFICATE OF COMPLETION BY Jesse Hartness DATE 15 Apr 76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold