HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: T6H-A-92
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: MIKE YORK OWNER: ✓ AGENT: PHONE: 876-2522
ADDRESS: 135 Polly DR APPLICATION DATE: 5/8/95 DATE EVALUATED: 5/8/95
STATESVILLE, NC 28677 PROPOSED FACILITY: 3BR House
PROPERTY SIZE: 4 ACRES
LOCATION OF SITE: HWY Road, 0.1 MILE ON (R) FROM SLOAN'S MILL RD.
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ✓ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS / SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	N 4%	0-42	C	SBK	1:1 / FI	.1942 WETNES CONDITION 5
		42-48	SC	WSBK/GR	1:1 / FR	.1943/.1956 SAPROLITE 5
						.1944 RESTRICTIVE HORIZON 5
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.3
2						.1942 WETNES CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
3						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
4						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
5						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR

AVAILABLE SPACE (.1945) 5 SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.3 GPD/FT2
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: MIKE YORK
COMMENTS:

DRAFT

00234