HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROP. ENV. I.D.#:
PROPERTY RECORDED: 16H-A-719
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: ASHLEY GREGORY OWNER: / AGENT: PHONE: 539-4316
ADDRESS: 1041 SLOANS MILL ROAD APPLICATION DATE: 4/17/95 DATE EVALUATED: 4/19/95
OLIN, NC 28660 PROPOSED FACILITY: 4 BR HOUSE
PROPERTY SIZE: 5.25 ACRES
LOCATION OF SITE: I-77 N, TL NC901, TL PIONEER, TR DRIVEWAY AT BOTTOM OF HILL
WATER SUPPLY: On-Site Well / Comm Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring / Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	L 6%	0-48	C	SBK	1:1 / FI	.1942 WETNESS CONDITION: S
						.1943/.1956 SAPROLITE: S
						.1944 RESTRICTIVE HORIZON: S
						.1948 PROFILE CLASSIFICATION: PS
						PROFILE LTAR: 0.35
2	N 8%	0-48	C	SBK	1:1 / FI	.1942 WETNESS CONDITION: S
						.1943/.1956 SAPROLITE: S
						.1944 RESTRICTIVE HORIZON: S
						.1948 PROFILE CLASSIFICATION: PS
						PROFILE LTAR: 0.35
3						.1942 WETNESS CONDITION: -
						.1943/.1956 SAPROLITE: -
						.1944 RESTRICTIVE HORIZON: -
						.1948 PROFILE CLASSIFICATION: -
						PROFILE LTAR: -
4						.1942 WETNESS CONDITION: -
						.1943/.1956 SAPROLITE: -
						.1944 RESTRICTIVE HORIZON: -
						.1948 PROFILE CLASSIFICATION: -
						PROFILE LTAR: -
5						.1942 WETNESS CONDITION: -
						.1943/.1956 SAPROLITE: -
						.1944 RESTRICTIVE HORIZON: -
						.1948 PROFILE CLASSIFICATION: -
						PROFILE LTAR: -

AVAILABLE SPACE (.1945): S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35
OTHER FACTORS(.1946): NONE SYSTEM TYPE: CONV. GRAVITY
EVALUATED BY: STEVE HEDRICK OTHER(S) PRESENT: JOE WEST
COMMENTS:

DRAFT

000420