37890

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

1176|

OWNER OR CONTRACTOR C. VANCE GREGORY DATE 9/10/90 PERMIT NO. 1811-A-64

Address, Business 634-5110 Home

LOCATION I-77 N, TO NC 901 ON (L) PAST SUMMER BARN

S. R. No.

SUBDIVISION NAME LOT NO. SECTION OR BLOCK NO.

House ( ) Mobile Home ( ) Business (✓) Other BANK W/ EXPANSION TO 2 MORE OFFICES

No. Bedrooms N/A No. Bathrooms 1+
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes ( ) No (✓)
Site Suitable Yes (✓) No ( )
Lot Area ANDLE

Character & Porosity of Soil PS
Percolation Rate 4
Topography 3-4%
Depth to Water Table 24"
Rock or other impervious formations NONE

Basement with Plumbing Basement without Plumbing ✓ No Basement

STB 9/14/90
Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1500 Linear Ft. 500
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Plot of System

Installed by

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed

IMPROVEMENTS PERMIT BY STEVE HEDRICK / GLENN FOX, JR

REMARKS ① USE SCH 40 - 4" PIPE FROM M.B. TO S.T. ~235'; AND,
② USE CLEANOUTS EVERY 50'

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 9/12/90

EXISTING SYSTEM CHECKED BY DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

This is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspectors Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold