37890

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

11761

OWNER OR CONTRACTOR C. VANCE GREGORY DATE 9/12/90 PERMIT NO. 161H-A-64

PHONE: Business 539-5110 Home

LOCATION I-77N, TL NC901 ON (L) PAST BURGER BARN

S. R. No.

SUBDIVISION NAME LOT NO. SECTION OR BLOCK NO.

House ( ) Mobile Home ( ) Business (✓) Other BANK W/ EXPANSION TO 2 MORE OFFICES

No. Bedrooms N/A No. Bathrooms 1+

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes ( ) No (✓)

Site Suitable Yes (✓) No ( )

Lot Area AMPLE

Character & Porosity of Soil PS

Percolation Rate 4

Topography 2-4%

Depth to Water Table >4'

Rock or other impervious formations NONE

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

STB 8/16/90

Size of Tank 1500 Gals.

Nitrification Field:


No. of Lines 4

Sq. Ft. 1500 Linear Ft. 500

Depth of Stone in Lines 12"

Water Supply: Individual ( )

Public (✓)



Plot of System

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY STEVE HEDRICK / GLENN FOX, JR

COMMENTS: ① USE SCH 40 - 4" PIPE FROM M.B. TO S.T. ~235'; AND,
② USE CLEANOUTS EVERY 50'

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 9/12/90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold