IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / CERTIFICATE OF COMPLETION / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PROPERTY DESCRIPTION NO. 67952 DATE 7-16-97 TAX MAP NO. 4852663629 Watershed: ☐ Yes ☐ No

OWNER OR CONTRACTOR Community Bank PHONE: Business 539-4000 Home

ADDRESS 1439 N memorial Hwy

LOCATION I-77 N TL 901 1/4 mi left.

SUBDIVISION BLOCK / SECTION LOT LOT AREA 1.0 acre SITE CLASS. PS DESIGN FLOW 200 L.T.A.R.

Septic Tank: 1500 Gallons; STB Date

Pump Tank: Gallons; PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 1500 Linear Feet 500

No Lines 4 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth 12"

☐ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description:

Repair System Description:

Maintenance Agreement Required: ☐ Yes ☐ No

☐ Slab ☐ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

☐ House/Mod. Home No. Bedrooms

☐ Mobile Home No. Bathrooms

☐ Business No. Employees 8

☐ Other Bank

Water Supply: ☐ Individual ☐ Community ☐ Public

Comments:

Comments: original Permit listed

3' X 125'
3' X 125'
3' X 125'
3' X 125'

INITIAL SITE SKETCH

AS BUILT SKETCH

C. Vance
Gregory

approx 200'

Bank Bldg

Memorial Hwy (901)

I understand that this permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit is valid for 60 months from date of issuance.

Signed:

Improvement Permit by: date

Existing System Inspection by: P. C. Moore date 7-16-97

Installed by: James Hustler

Certificate of Completion by: Steve Hetrick date 9-12-90

Operation Permit by: date

HEALTH DEPT. COPY: WHITE INSPECTION COPY (FINAL): GREEN OWNER COPY (FINAL): YELLOW INSPECTION COPY (INITIAL): PINK OWNER COPY (INITIAL): GOLD