IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jerry L. Morgan DATE 8-4-82 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION I-77 N - TR 1901 E - TR 1849 Go Approx. 3/4 Mile. Mobile Home on Rt. S. R. No. _____


SUBDIVISION NAME _____ LOT NO. 2 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____ Prov. Suitable

No. Bedrooms	3	No. Bathrooms	1½	Character & Porosity of Soil	C-7B-2
Garbage Disposal Unit	Yes ( )	No	(✓)	Percolation Rate	
Auto. Dishwasher	Yes (✓)	No	( )	Topography	2-6% Slope
Auto. Wash. Machine	Yes (✓)	No	( )	Depth to Water Table	
Site Suitable	Yes (✓)	No	( )	Rock or other impervious formations	None

Lot Area _____

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 750 Linear Ft. 250

Depth of Stone in Lines 16"

Water Supply: Individual ( )

Public (✓)

Installed by James Hutchens

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steven Foard Jr. DATE 8/4/82

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold