03978

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption) Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Whitley Johnson DATE 4/6/86 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION I-77 N - Then 90 E Then SR 1849 Turn Rt. Mobile Home on left just Mostley Chapel

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____ S. R. No. 1849

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 1 Acre

Character & Porosity of Soil Clay Sandstone


Percolation Rate 25 Sec avg 45 Sec Max

Topography 2 - 6%

Depth to Water Table 10'

Rock or other impervious formations None

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 720 Linear Ft. 240

Depth of Stone in Lines 12"

Water Supply: Individual ( )

Public (✓)

Installed by Jimmy Hartman & Co.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Mr. Kelly Shuler RS

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 4/6/86

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold