03711

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Blaine Hasue DATE 12/27/85 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION I 77 N, LF on 901 Rt on Howard Bridge, Modular Home on Rt before Hunting Creek Bridge

SUBDIVISION NAME _____ S. R. No. _____

LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other Modular

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No ( )
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area _____

Character & Porosity of Soil Good Suitable


Percolation Rate Good fft²

Topography 2-6%

Depth to Water Table 10ft

Rock or other impervious formations scattered rock

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 900+ Linear Ft. 390 **

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by Oliver Campbell

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: System installed in ≈30" ditches. 2 Concrete Dams installed in lines [redacted] #2 & #3 due to too much fall in lines. Tank ≈131 from Modular home basement OK'D by Mr Blaine Hasue

CERTIFICATE OF COMPLETION BY _____ DATE 12/27/85

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold