DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: ____
COUNTY: TYRRELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: BARRY J. WILLIAMS APPLICANT: SAME
ADDRESS: 164 HOMESTEAD RD, HERTFORD APPLICATION DATE: 10-19-01 DATE EVALUATED: 11-20-01
PROPOSED FACILITY: 3BR(H)W/BMT PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 4.54 ACRES
LOCATION OF SITE: 1355 UNION GROVE ROAD, UNION GROVE PROPERTY RECORDED: ____
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other ____
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	L 8%	0-8	WSBK / GRAVELLY CL	FR / SEXP					PS 0.3
		8-54	SBK C	FR / SEXP					
2	SLIGHT H 8%	0-12	WSBK / GRAVELLY CL	FR / SEXP					PS 0.3
		12-56"	SBK / C	FR / SEXP					
3	L 10%	0-12	WSBK / GRAVELLY CL	FR / SEXP					PS 0.3
		12-54	SBK / C	FR / SEXP					
4	L 8%	0-24	SBK / CL	FR / SEXP					PS 0.3
		24-48	SBK / C	FR / SEXP					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	III
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HODGE
OTHER(S) PRESENT: BARRY WILLIAMS / DALE WILLIAMS (BACKHOE)