03622

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Norris Bridges DATE 11-[illegible]-85 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION I-77 N - Take Exit 101 - Main Street, Troutman SR 1832 - Turn on SR 1816 South - 2nd - Turn Right Sixth Rd. - Fifth House on Left S. R. No. 1816


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay Loam	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	30 min per inch	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Gently Sloping	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	[illegible]	
Lot Area 1 Acre			Rock or other impervious formations	[illegible]	

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Notification Field:
No. of Lines 2
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Jean Hartsell

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Jean Hartsell DATE 11/19/85

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold