IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

12019 MICHAEL, ANDREA & DUSTIN MARLOW

OWNER OR CONTRACTOR BETTY BRIDGES DATE 10/15/92 PERMIT NO. 16J-A-2

PHONE: Business _____ Home _____

LOCATION I-77 N, TL NC 901 W, TR MULLIS ROAD, TR ZION LIBERTY ROAD, ON (R) JUST PAST SPRING. S.R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

S/W

House ☐ Mobile Home ☑ Business ☐ Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ☐ No ☑

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area AMPLE

Soil Characteristics PS


Application Rate 0.35 GPD / FT2

Topography 10-15% LINEAR

Depth to Water Table >4'

Rock or other impervious formations NONE NOTED

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement ✓ Crawl Space



Plot of System (Not to Scale)

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 690 Linear Ft. 230

Depth of Stone in Lines 12"

Water Supply: Individual ☑ SPRING

Public ☐

Installed by A-1 BACKHOE

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY STEVE HEDRICK

COMMENTS REPAIR AREA IS 100% CONVENTIONAL GRAVITY-FED

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 10/15/92

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold