IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Deaner Chambers DATE 25 July 74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 N to Mooresville - 901 to Union Grove - T.R. in front of school. Go to 1st R^d 186 on Right. Go 1/2 M^e to R^d 1817 on left. Go 1/2 M^e Trailer on right. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cly Loam
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	fair
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope front
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	well
			Rock or other impervious formations	Rock

Lot Area 1 acre



Plot of System Rd 1817

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 621 Linear Ft. 250
Depth of Stone in Lines 16"

Water Supply: Individual (✓)
Public ( )
Water from Father well.

Installed by Henry Norman

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY William M. Howard DATE 25 July 74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold