DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #:
COUNTY: IREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: A-1 Mobile Homes APPLICANT: Roger Templeton
ADDRESS: 590 Mocksville Hwy, Stvl, 28677 APPLICATION DATE: 9-29-99 DATE EVALUATED: 10-13-99
PROPOSED FACILITY: 3BR DW MH PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 0.54 ACRE
LOCATION OF SITE: HEATHSTEAD # 11 PROPERTY RECORDED: ____
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other ____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	L 6%	0-6	GR / SCL	VFR / NEXP					PS 0.3
		6-34	SBK / C	FI / NEXP					
		34-48	SBK / SC	FR / NEXP					
2	L 8%	0-4	GR / SCL	VFR / NEXP					PS 0.35
		4-30	SBK / C	FI / NEXP					
		30-48	SBK / SC	FR / NEXP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	II	II
Site LTAR	0.35	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HEDRICK
OTHER(S) PRESENT: Roger Templeton