(54)

# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

12800

OWNER OR CONTRACTOR TERRY D. PADGETT DATE 8/19/91 PERMIT NO. 12 P-A-37A

PHONE: Business _____ Home _____

LOCATION US 21N, TR TABOR RD, TL DUNCAN RD, 1ST LOT ON (L)

SUBDIVISION NAME _____ S. R. No. _____

LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 2 No. Bathrooms 2

| | | | | |
|---|---|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No (✓) | Character & Porosity of Soil | PS |
| Auto. Dishwasher | Yes (✓) | No ( ) | Percolation Rate | .4 GPA / FT2 |
| Auto. Wash. Machine | Yes (✓) | No ( ) | Topography | 1-6% NS |
| Site Suitable | Yes (✓) | No ( ) | Depth to Water Table | >4' |
| | | | Rock or other impervious formations | NONE |

Lot Area 3.40 AC

✓ Basement with Plumbing _____ Basement without Plumbing _____ No Basement

TP 1/16/91




Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. ~~600~~ 900 Linear Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual (✓) WELL

Public ( )

Installed by Tommy Frye

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY STEVE HEDRICK

COMMENTS: 300 LF INSTALLED AT REQUEST OF OWNER

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 8/19/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold