DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of _
PROPERTY ID #:
COUNTY: ~~IREDELL~~

4860-65-6260

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: HAROLD ENGLISH APPLICANT: SAME
ADDRESS: 802 CREST RACE ROAD, STE 28677 APPLICATION DATE: 3-7-02 DATE EVALUATED: 3-21-02
PROPOSED FACILITY: 3BR S/W MH PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 0.52 ACRE
LOCATION OF SITE: FORNEY ACRES LOT #24 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	L 6%	0-30	SBK C	FI SLXP					PS 0.3
		30-48	SBK MICACEOUS C	FR SLXP					
2	SLIGHT H 6%	0-38	SBK C	FI SLXP					PS 0.3
		38-48	SBK MICACEOUS C	FR SLXP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	PS
System Type(s)	II	III
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: STEVE HEDRICK
OTHER(S) PRESENT: _____