DEPARTMENT OF ENVIRONMENT, HEALTH AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION *for* ON-SITE WASTEWATER SYSTEM

4861-33-4032

OWNER: HORNE BUILDING, INC APPLICANT: JEFF HORNE
ADDRESS: 254 FAIRWOOD ST VC APPLICATION DATE: 7-11-01 DATE EVALUATED: 8-19-01
PROPOSED FACILITY: 3BR H PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 0.51 AC
LOCATION OF SITE: PADGETT FARMS #5 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAF
1	H 6%	0-12	GR SL	VFR	PS 5Y 8/1				PS 0.25
		12-48	SBK/ABK C	FI S/P SEXP					
2	H 4%	0-14	GR SL	VFR	PS 5Y 8/1				PS 0.25
		14-48	SBK/ABK C	FI S/P SEXP					
3	L 4%	0-8	GR SL	VFR					
		8-48	SBK C	FI S/P SEXP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	III	III
Site LTAR	0.25	0.25

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HADDOCK
OTHER(S) PRESENT: JEFF HORNE