DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #:
COUNTY: IREDELL

4861-75-3081.B

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: FLEETWOOD HOMES OF STVL APPLICANT: SAME
ADDRESS: 1270 NORTHSIDE DR STVL APPLICATION DATE: 6-3-02 DATE EVALUATED: 7-1-02
PROPOSED FACILITY: 5 BR D/W PROPOSED DESIGN FLOW (.1949): 600 PROPERTY SIZE: 1.0 ACRE
LOCATION OF SITE: 4S 21 N TL TABOR RD TR DUTCHMAN RD, .08 mi on LFT PROPERTY RECORDED:
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	L 10%	0-16	SBK CL	FR SEXP	CHROMA 2 @ 16"+				PS 0.3
		16-48	SBK SiCL	FR SEXP					
2	SLIGHT H 12%	0-14	SBK CL	FR SEXP	CHROMA 2 @ 14"+				PS 0.3
		14-48	SBK SiCL	FR SEXP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	PS
System Type(s)	II	II
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HENDRICK
OTHER(S) PRESENT: BRIAN SIGMON