DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of _
PROPERTY ID #:
COUNTY: [illegible]

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

4861 87 7099

OWNER: Jimmy Steele APPLICANT: Johnathon Mitchell
ADDRESS: 143 Yorkspann Rd APPLICATION DATE: 11-7-00 DATE EVALUATED: 11-11-00
PROPOSED FACILITY: ~~SFR~~ D/WMH PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: 3.51
LOCATION OF SITE: NC 901 at Allen Road PROPERTY RECORDED: ___
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	L 10%	0-8	MMSBK C	FI SS/SP/SEXP					PS 0.3
		8-22	WMSBK C	FI SS/SP/SEXP					
		22-48	WMSBK SCL	SAPROLITE MIX			PS		
2	L 8%	0-10	MMSBK/C	FI SS/SP SEXP					PS 0.3
		10-24	WMSBK/C	FI S/P SEXP					
		24-48	WFSBK SCL	SAPROLITE MIX			PS		
3	L 6%	0-8	MMSBK C	FI S/P SEXP					PS 0.3
		8-30	WMSBK C	FI SS/SP SEXP					
		30-48	WFSBK SCL	SAPROLITE MIX			PS		
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	II
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. Hedrick, Louise Cook
OTHER(S) PRESENT: Jimmy Steele JR & SR, David Lumbarger