(Trailer space for David Carter)

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Henry Carter DATE 25 July 74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION NW to Tobe Cl. Rd. Lt to 901 - T.L. on 901. Happers. 1 mile Trailer on Lft. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Red Clay Loam


Percolation Rate none

Topography Slope E NW

Depth to Water Table ok

Rock or other impervious formations ok

Lot Area acreage



Plot of System Hwy 901

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Henry Carter

IMPROVEMENTS PERMIT BY _____

COMMENTS: Drain all surface water away from drain area & tank.

CERTIFICATE OF COMPLETION BY William M Stewart DATE 25 July 74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold